

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 2280-1321:102 Page 1 of 1

CATEGORY: Coating Materials

LISTEE: SWD Urethane, 222 S. Date Street, Mesa, AZ 85210
Contact: Ron Whipple (602) 969-8413

DESIGN: SWD1929F general purpose fire retardant chemical coating. For use as finish coating applied to noncombustible surfaces such as inorganic, reinforced boards. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Flame spread rating requires application of 2 coats at the rate of 33 square feet per gallon for each coat.

Flame Spread:	15
Smoke Dev:	10

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product label and UL label.

APPROVAL: Listed as a coating material for application to noncombustible interior wall and ceiling surfaces to reduce flame spread when the coatings are applied at the rates specified.

02-08-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 15, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager